



APPROX. LOCATION OF WASTEWATER DRAIN LINE- CONTINUE 5' PAST BUILDING

APPROX. LOCATION OF UNDERGROUND ELECTRIC CONDUIT AND DATA WIRING CONDUIT, CONTINUE 5' PAST BUILDING

PLUMBING NOTES-
THE SELECTED CONTRACTOR WILL BE GIVEN A MORE DETAILED DRAWING SHOWING THE LOCATION OF THE TOILET, SHOWER, URINAL, FLOOR DRAIN AND AIR VENT.
WASTEWATER- MAIN LINE SHALL BE 4" SCHED. 40 ABS, MIN DEPTH BELOW FIN. GRADE OF 8", AND SLOPE TO WEST AT APPROX. 2%. INCLUDES ROUGH-IN FOR TOILET, SHOWER, URINAL, AIR VENT, AND FLOOR DRAIN IN MECHANICAL ROOM. THESE FIXTURE ROUGH-INS MAY USE PIPE SIZES LESS THAN 4" DIAMETER.
WATER LINE- SHALL BE 1" TYPE K COPPER, MIN. DEPTH BELOW FIN. GRADE OUT-SIDE BUILDING OF 3', AND BE WRAPPED IN FOAM PIPE INSULATION.
ELECTRIC LINE AND DATA LINE- EACH SHALL BE 4" SCHED. 40 PVC ELECTRIC, MIN. BURIAL DEPTH OF 18". USE SWEEP EL'S AT ALL TURNS.

LINCOLN NATIONAL FOREST		CLLOUDCROFT WAREHOUSE	PLUMBING PLAN		SHEET 5 OF 5
-------------------------	--	-----------------------	---------------	--	--------------